FSIF10DD

| CFM | Static Pressure in Inches W.G. | | | | |
|-----|--------------------------------|---------------------|---------------------|---------------------|---------------------|
| | 0.000 | 0.250 | 0.500 | 0.750 | 1.000 |
| | RPM Sone/BHP | RPM Sone/BHP | RPM Sone/BHP | RPM Sone/BHP | RPM Sone/BHP |
| 100 | | 847 3.9 / 0.02 | 1176 7.1 / 0.05 | | a. |
| 200 | | 917 4.5 / 0.03 | 1235 7.8 / 0.06 | 1481 10.8 / 0.11 | 1695 13.6 / 0.16 |
| 300 | 570 1.7 / 0.01 | 1014 5.4 / 0.05 | 1316 8.8 / 0.08 | 1554 11.8 / 0.13 | 1754 14.4 / 0.18 |
| 400 | 759 3.4 / 0.02 | 1136 6.8 / 0.08 | 1413 10.0 / 0.12 | 1639 13.0 / 0.17 | ı' |
| 500 | 949 5.2 / 0.05 | 1272 8.6 / 0.11 | 1529 11.7 / 0.17 | 1742 14.2 / 0.23 | |
| 600 | 1136 7.1 / 0.08 | 1418 10.7 / 0.15 | 1653 13.6 / 0.24 | | r- |
| 700 | 1326 9.6 / 0.13 | 1573 13.3 / 0.21 | | | r. |
| 800 | 1515 12.5 / 0.19 | | | | - |

Max Sizeable RPM = 1800 RPM. Table shown extended beyond this point for reference only.

Motor BMN42-180I1-50-115 has an rpm range of 300 to 1800.

Motor BMN42-180I1-60-115 has an rpm range of 300 to 1800.

Motor BMN42-180l2-50-230/277 has an rpm range of 300 to 1800.

Motor BMN42-180I2-60-230/277 has an rpm range of 300 to 1800.

Motor CK42BS04M01-50-115 has an rpm range of 1100 to 1400.

Motor CK42BS04M01-50-230 has an rpm range of 1100 to 1400.

Motor CK42BS04M01-60-115 has an rpm range of 1125 to 1620.

Motor CK42BS04M01-60-230 has an rpm range of 1125 to 1620.

Performance shown is certified for Installation Type B: Free inlet, Ducted outlet. Performance ratings do not include the effects of appurtenances in the airstream. Power rating (BHP) includes transmission losses. The sound ratings shown are loudness values in sones at 5 ft (1.5m) in a hemispherical free field calculated per AMCA Standard 301. Installation type B: free inlet hemispherical sone levels. Ratings do not include the effect of duct end correction.

FloAire certifies that the FSIF10DD shown herein is licensed to bear the AMCA seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 211 and 311 and complies with the requirements of the AMCA Certified Ratings Program. Tested to AMCA Standards 210 and 300. Meets California Energy Commission (CEC) Title 20 Regulations.

Catalog #110F May 2024

