



IMPORTANT

Remove jumper between terminal I & C before connecting interlocks.
 Wire in accordance with local & Canadian Electrical codes. Read instructions carefully before wiring and operating.
 Frame shown in heavy line represents Thermolec Electric Coil. All wiring outside this frame are "typical external wiring by others".

LEGEND

- A Automatic Reset Cut Out
- M Manual Reset Cut Out
- C1,C2 Operating Contactors
- DISC Disconnect Switch
- D46 Solid State Controller
- F Fuse Or Fuse Link
- PDS Pressure Differential Switch
- SSR Solid State Relay
- T Control Circuit Transformer
- CM Back-up Contactor to Manual

TITLE/TITRE



THERMOLEC

MONTREAL - CANADA

LTEE
LTD

DRAWING NO. 3B5E-7M4U-B600-0000

DATE

PER